

## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER  
 TYPE : MULTI SPLIT  
           : WALL MOUNTED  
 Indoor unit(s) : ASEH07KMCG x 5  
 Outdoor unit : AOE36KBTA5  
 BRAND : FUJITSU

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	9.5	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	7.0	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	9.50	kW	Tj = 35°C	EER d	3.80	-
Tj = 30°C	Pdc	7.00	kW	Tj = 30°C	EER d	5.84	-
Tj = 25°C	Pdc	4.50	kW	Tj = 25°C	EER d	10.31	-
Tj = 20°C	Pdc	2.08	kW	Tj = 20°C	EER d	17.11	-

Heating/Average				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	6.19	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	3.77	kW	Tj = 2°C	COPd	4.72	-
Tj = 7°C	Pdh	4.06	kW	Tj = 7°C	COPd	6.11	-
Tj = 12°C	Pdh	3.89	kW	Tj = 12°C	COPd	7.71	-
Tj = bivalent temperature	Pdh	6.19	kW	Tj = bivalent temperature	COPd	3.01	-
Tj = operating limit*	Pdh	5.85	kW	Tj = operating limit*	COPd	2.96	-

Heating/Warmer				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COPd	N/A	-

Heating/Colder				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	T <sub>biv</sub>	-7	°C	Heating/Average	T <sub>ol</sub>	-15	°C
Heating/Warmer	T <sub>biv</sub>	N/A	°C	Heating/Warmer	T <sub>ol</sub>	N/A	°C
Heating/Colder	T <sub>biv</sub>	N/A	°C	Heating/Colder	T <sub>ol</sub>	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	P <sub>cycc</sub>	N/A	kW	For cooling	EER <sub>cycc</sub>	N/A	-
For heating	P <sub>cycc</sub>	N/A	kW	For heating	COP <sub>cycc</sub>	N/A	-
Degradation coefficient cooling	C <sub>dc</sub>	0.25	-	Degradation coefficient heating	C <sub>dh</sub>	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P <sub>OFF</sub>	5.0/5.0	W	Cooling	Q <sub>CE</sub>	391	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	5.0/5.0	W	Heating/Average	Q <sub>HE</sub>	2126	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	11.0/23.0	W	Heating/Warmer	Q <sub>HE</sub>	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P <sub>CK</sub>	0.0/0.0	W	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a

Capacity control		Other items			
Item	Y/N	Item	Symbol	Value	Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	54.0/65.0	dB(A)
Staged	No	Global warming potential	GWP	675	kgCO <sub>2</sub> eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	650/2450	m <sup>3</sup> /h

Contact details for obtaining more information	FUJITSU GENERAL LIMITED 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	---

\* : Temperature at part load E condition(EN 14825)

V20121214

Information of indoor unit combination

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit <sup>*1</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	rooms	Design load kW	Seasonal efficiency SEER	Annual electricity consumption kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/A	Annual electricity consumption kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOPW	Annual electricity consumption kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/C	Annual electricity consumption kWh/a	Energy efficiency class
07	24	-	-	-	9.0	7.9	399	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	7.9	377	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	8.2	320	A++	6.0	4.5	1867	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder				
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	
					Pdesigngh	SEER	Q <sub>CE</sub>	Pdesigngh	SCOP/A	Q <sub>HE</sub>	Pdesigngh	SCOP/W	Q <sub>HE</sub>	Pdesigngh	SCOP/C	Q <sub>HE</sub>					
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	
09	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	-	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	-	8.5	8.4	354	A++	6.8	4.5	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	-	8.0	8.4	375	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

\*1  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit <sup>1</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Colder				
room1	room2	room3	room4	room5	Design load kW	Seasonal efficiency SEER	Annual electricity consumption Q <sub>CE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/A	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/W	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/C	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	
																					Pdesignch
07	07	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	08	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1</sup>  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit <sup>1</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Colder				
room1	room2	room3	room4	room5	Design load kW	Seasonal efficiency SEER	Annual electricity consumption C <sub>oE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/A	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/W	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/C	Annual electricity consumption Q <sub>HE</sub> kWh/a	Energy efficiency class	
																					Pdesigngh
09	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1</sup>  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit <sup>1)</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Colder				
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	
					Pdesignch	SEER	Q <sub>CE</sub>	-	Pdesignh	SCOP/A	Q <sub>HE</sub>	-	Pdesignw	SCOP/W	Q <sub>HE</sub>	-	Pdesignh	SCOP/C	Q <sub>HE</sub>	-	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	
07	07	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1)</sup>  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED KG/KM/KE type)

N/A = Not Applicable

Combination of indoor unit <sup>1)</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Coldst <sup>2)</sup>			
room1	room2	room3	room4	room5	Design load kW	Seasonal efficiency SEER	Annual electricity consumption C <sub>0,IE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/A	Annual electricity consumption Q <sub>0,IE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOPW	Annual electricity consumption Q <sub>0,IE</sub> kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOPC	Annual electricity consumption Q <sub>0,IE</sub> kWh/a	Energy efficiency class
05	22	-	-	-	7.5	6.1	430	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	-	-	-	9.5	6.0	496	A+	6.8	4.0	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	-	9.0	6.0	525	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	6.0	496	A+	6.8	4.0	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	22	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	14	-	-	9.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	6.3	417	A++	6.9	4.2	2000	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1)</sup>  
 05 = 5000Btu/h class = 1.5kW class  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class





Indoor unit combination (except all indoor unit WALL MOUNTED KG/KM/KE type)

N/A = Not Applicable

Combination of indoor unit <sup>1</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Coldst <sup>2</sup>			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignkw	SEER	QcE	-	Pdesigngh	SCOP/A	QhE	-	Pdesigngh	SCOPW	QhE	-	Pdesigngh	SCOPC	QhE	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1</sup>  
 05 = 5000Btu/h class = 1.5kW class  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class





Indoor unit combination (except all indoor unit WALL MOUNTED KG/KM/KE type)

N/A = Not Applicable

Combination of Indoor unit <sup>1)</sup>					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngh kW	SEER	QcE kWh/a	-	Pdesigngh kW	SCOP/A	QhE kWh/a	-	Pdesigngh kW	SCOPW	QhE kWh/a	-	Pdesigngh kW	SCOPC	QcE kWh/a	-
07	07	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

<sup>1)</sup>  
 05 = 5000Btu/h class = 1.5kW class  
 07 = 7000Btu/h class = 2.0kW class  
 09 = 9000Btu/h class = 2.5kW class  
 12 = 12000Btu/h class = 3.5kW class  
 14 = 14000Btu/h class = 4.0kW class  
 18 = 18000Btu/h class = 5.0kW class  
 22 = 22000Btu/h class = 6.0kW class  
 24 = 24000Btu/h class = 7.0kW class

Information of unit specification

Model Type	Model No.	Capacity Class	Dimension [H x W x D]	Sound power level(Cooling)	Sound power level(Heating)
		kW	mm	dB(A)	dB(A)
OUTDOOR	AOEG36KBT A5	-	884 x 820 x 315	65	68
WALL MOUNTED	ASEH05KNCA	1.5	270 x 784 x 222	50	50
	ASEH07KNCA	2.0		51	51
	ASEH09KNCA	2.5		56	56
	ASEH12KNCA	3.5		57	57
	ASYG07KMCF ASEH07KMCG ASEH07KMCG-B	2.0	270 x 834 x 222	54	56
	ASYG09KMCF ASEH09KMCG ASEH09KMCG-B	2.5		55	57
	ASYG12KMCF ASEH12KMCG ASEH12KMCG-B	3.5		55	58
	ASYG14KMCF ASEH14KMCG ASEH14KMCG-B	4.0		57	59
	ASYG07KGTG ASEH07KGTG	2.0	270 x 834 x 215	54	56
	ASYG09KGTG ASEH09KGTG	2.5		55	57
	ASYG12KGTG ASEH12KGTG	3.5		56	58
	ASYG14KGTG ASEH14KGTG	4.0		57	59
	ASYG18KMTE ASEG18KMTE	5.0	280 x 980 x 240	60	61
	ASYG22KMTE ASEG22KMTE	6.0		62	62
	ASYG24KMTE ASEG24KMTE	7.0		65	65
	ASYG07KETF ASEG07KETF ASYG07KETF-B ASEG07KETF-B	2.0	295 x 950 x 230	54	56
	ASYG09KETF ASEG09KETF ASYG09KETF-B ASEG09KETF-B	2.5		55	57
	ASYG12KETF ASEG12KETF ASYG12KETF-B ASEG12KETF-B	3.5		55	58
	ASYG14KETF ASEG14KETF ASYG14KETF-B ASEG14KETF-B	4.0		57	59
	CASSETTE	AUXG07KVLA	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46
AUXG09KVLA		2.5	46		47
AUXG12KVLA		3.5	49		49
AUXG14KVLA		4.0	50		55
AUXG18KVLA		5.0	50		55
AUXG22KVLA		6.0	56		57
DUCT	ARXG07KSLAP	2.0	198 x 700 x 450	52	53
	ARXG09KSLAP	2.5		54	56
	ARXG12KSLAP	3.5		55	57
	ARXG14KSLAP	4.0		60	62
	ARXG18KSLAP	5.0	198 x 900 x 450	58	59
	ARXG07KLLAP	2.0	198 x 700 x 620	57	57
	ARXG09KLLAP	2.5		57	57
	ARXG12KLLAP	3.5		58	58
	ARXG14KLLAP	4.0		60	60
	ARXG18KLLAP	5.0	198 x 900 x 620	58	58
	ARXG22KMLB	6.0	270 x 1135 x 700	60	62
	ARXH12KMTAP	3.5	240 x 700 x 700	58	58
	ARXH14KMTAP	4.0		59	59
	ARXH18KMTAP	5.0		60	60
ARXH22KMTAP	6.0	240 x 1000 x 700		58	58
FLOOR	AGYG09KVCA AGEG09KVCA	2.5	600 x 740 x 200	52	52
	AGYG12KVCA AGEG12KVCA	3.5		55	55
	AGYG14KVCA AGEG14KVCA	4.0		56	56
CEILING	ABYG18KRTA ABEG18KRTA	5.0	235 x 1080 x 705	53	53
	ABYG22KRTA ABEG22KRTA	6.0		57	57