## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER SINGLE SPLIT WALL MOUNTED ASYG07KPCA AOYG07KPCA FUJITSU Indoor unit(s) Outdoor unit BRAND

TYPE

N/A = Not Applicable

Function							
Cooling	Yes	Average	Yes				
Heating Yes Warmer Yes							
		Colder	No				

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	2.0	kW	Cooling	SEER	6.70	-
Heating/Average	Pdesignh	2.2	kW	Heating/Average	SCOP/A	4.00	-
Heating/Warmer	Pdesignh	1.2	kW	Heating/Warmer	SCOP/W	5.00	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj			Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outcome.	loor temper	ature Tj		
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	2.00	kW	Tj = 35°C	EER d	4.17	-
Tj = 30°C	Pdc	1.47	kW	Tj = 30°C	EER d	6.40	-
Tj = 25°C	Pdc	1.17	kW	Tj = 25°C	EER d	9.00	-
Tj = 20°C	Pdc	1.16	kW	Tj = 20°C	EER d	10.54	-

Heating/Average								
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Averat indoor temperature 20 °C and outdoo	,			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Tj = -7°C	Pdh	1.95	kW	Tj = -7°C	COPd	2.46	-	
Tj = 2°C	Pdh	1.18	kW	Tj = 2°C	COPd	4.08	-	
Tj = 7°C	Pdh	0.76	kW	Tj = 7°C	COPd	5.07	-	
Tj = 12°C	Pdh	0.88	kW	Tj = 12°C	COPd	6.28	-	
Tj = bivalent temperature	Pdh	1.95	kW	Tj = bivalent temperature	COPd	2.46	-	
Tj = operating limit	Pdh	2.13	kW	Tj = operating limit	COPd	2.24	-	

Heating/Warmer									
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warm at indoor temperature 20 °C and outdoor te		Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit		
Tj = 2°C	Pdh	1.18	kW	Tj = 2°C	COPd	4.08	-		
Tj = 7°C	Pdh	0.76	kW	Tj = 7°C	COPd	5.07	-		
Tj = 12°C	Pdh	0.88	kW	Tj = 12°C	COPd	6.28	-		
Tj = bivalent temperature	Pdh	1.18	kW	Tj = bivalent temperature	COPd	4.08	-		
Tj = operating limit	Pdh	2.13	kW	Tj = operating limit	COPd	2.24	-		

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	=:
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	=:
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	6
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COP d	N/A	~
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature			Operating limit temperature				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	-15	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity			Cycling interval efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	
For heating	Pcych	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-:

Electric power input in power modes other than 'active mode'			Annual electricity consumption				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P <sub>OFF</sub>	5.0/5.0	W	Cooling	Q <sub>CE</sub>	104	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	5.0/5.0	W	Heating/Average	Q <sub>HE</sub>	769	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	1.0/9.0	W	Heating/Warmer	Q <sub>HE</sub>	330	kWh/a
Crankcase heater mode (Cooling/Heating)	P <sub>CK</sub>	0.0/0.0	W	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a

Capacity control	Other items				
Item	Y/N	Item	Symbol	Value	Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	57.0/57.0	dB(A)
Staged	No	Global warming potential	GWP	675	kgCO₂eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	580/1650	m³/h

	FUJITSU GENERAL LIMITED
Contact details for obtaining more information	3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan

V20121214